



Number	KIP0001330A/01	Replaces	KIP0001330A/00
Issued	10/07/2017	First edition	23/06/2016
Report number	PKC0001330	Page	1 of 2

Certificate of Type Testing Conformity

License holder: Peimar S.r.l.
Via Creta 72 – 25124 Brescia (BS), Italy

Production site ref. nr.: PKC0001330

Product: Grid-tied Photovoltaic (PV) inverter

Models: PSI-1100TL; PSI-1600TL; PSI-2200TL; PSI-2700TL; PSI-3000TL

The products can be considered complying to the type testing based upon the following aspects:

- CEI 0-21:2014-09 + CEI 0-21;V1:2014-12 + CEI 0-21:2016-07
Reference technical rules for the connection of active and passive users to the LV electrical utilities.
Remarks: the product complies with the Annex A and B of the standard CEI 0-21.

This type testing certificate is only valid for the sample tested with the configuration described on the test report.

This type testing certificate does not include the Initial and the Periodic Inspection of the production samples.

*This certificate is issued in accordance with the Kiwa Cermet Italia regulations for Product Certification.
Publication of the certificate is allowed.*

Chief Operating Officer
Giampiero Belcredi

Member of the IECCE CB-Scheme

Kiwa Cermet Italia S.p.A.

Società con socio unico, soggetta all'attività di direzione e coordinamento di Kiwa Italia Holding Srl

Via Cadriano, 23
40057 Granarolo dell'Emilia (BO)

Unità secondaria

Via Treviso 32/34
31020 San Vendemiano (TV)

Tel +39. 0438 411755

Fax +39.0438 22428

E-mail: info@kiwacermet.it

www.kiwa.it

www.kiwacermet.it

Certificate



Number KIP0001330A/01 Replaces KIP0001330A/00
 Issued 10/07/2017 First edition 23/06/2016
 Report number PKC0001330 Page 2 of 2

Certificate

Certificate of Type Testing Conformity Annex

Declaration of Conformity to CEI 0-21:2014-09 + CEI 0-21;V1:2014-12 + CEI 0-21:2016-07
 "Reference technical rules for the connection of active and passive users to the LV electrical Utilities".

TYPE OF APPARATUS WHICH THE DECLARATION IS REFERRED TO:

Interface Device	Interface Protection Device	Static Conversion Device	Rotating Device
<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>

Manufacturer	Peimar S.r.l. Via Creta 72 – 25124 Brescia (BS), Italy
Product type	Grid-tied Photovoltaic (PV) inverter
Model name	PSI-1100TL; PSI-1600TL; PSI-2200TL; PSI-2700TL; PSI-3000TL
Firmware release	V1.0
Number of Phases	Single-phase
Nominal Power	1000VA; 1550VA; 2100VA; 2600VA; 3000VA
Remarks	<input checked="" type="checkbox"/> The device is capable to limit the Idc to 0.5% of the nominal current <input type="checkbox"/> The device needs to be coupled with an external insulation transformer <input type="checkbox"/> The device is equipped with a low frequency insulation transformer
Test laboratory	Bureau Veritas Consumer Products Services Germany GmbH (EA accredited laboratory DAKs n° D-PL-12024-03-01; STC (Dongguan) Company Limited (EA accredited laboratory DAKs n° D-PL-12121-01-00)


Having assessed the Test Files n° 16TH0076-CEI 0-21_0 and 16TH0076-CEI 0-21_1 issued by Bureau Veritas Consumer Products Services Germany GmbH (EA accredited laboratory DAKs n° D-PL-12024-03-01) and n° DM122441 (EMC test) issued by STC (Dongguan) Company Limited (EA accredited laboratory DAKs n° D-PL-12121-01-00).

Having examined the ISO 9001 certificate of the manufacturer n° 04916Q11710R1M.

We declare that the products indicated meet the requirements laid down by CEI 0-21:2014-09 + CEI 0-21;V1:2014-12 + CEI 0-21:2016-07 "Reference technical rules for the connection of active and passive users to the LV electrical Utilities".

Date of issue: 10/07/2017

Chief Operating Officer
Giampiero Belcredi



Kiwa Cermet Italia S.p.A.

Società con socio unico, soggetta all'attività di direzione e coordinamento di Kiwa Italia Holding Srl

Via Cadriano, 23
40057 Granarolo dell'Emilia (BO)

Unità secondaria

Via Treviso 32/34
31020 San Vendemiano (TV)

Tel +39. 0438 411755

Fax +39.0438 22428

E-mail: info@kiwacermet.it

www.kiwa.it

www.kiwacermet.it